

2021 Water Quality Report for CITY OF CRYSTAL FALLS

This report covers the drinking water quality for the City of Crystal Falls, for the calendar year 2021. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

In 2007 we transitioned, for water quality purposes, to purchasing water from Crystal Falls Township. An additional well, with our help, was drilled at their Lind site for added capacity.

We no longer need to treat the water for iron removal. Our well #1 has been properly abandoned.

For more information, contact the clerk's office at 401 Superior Avenue, Crystal Falls, MI 49920. Call 906-875-3212.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **USEPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
- Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture and residential uses.

Radioactive contaminants, which are naturally occurring or could be the result of oil and gas production and mining activities.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data – Purchased Ground Water

The table below lists all the drinking water contaminants that we detected during the 2021 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2021. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or **micrograms per liter ppm:** parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radioactivity).
- **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Regulated Contaminant	MCL	MCLG	Level Detected	Sampled	Violation Yes / No	Typical Source of Contaminant
Fluoride (ppm)	4	4	ND	2015	No	Erosion of natural deposits
Unregulated Contaminant*						
Sodium (ppm)			ND	2015	No	Erosion of natural deposits.
Contaminant Subject to AL	Action Level	90% of Samples < This Level	Sampled			Range of All Samples Lowest / Highest
Lead (ppb)	15	1.0	9/20	No		0.1ppb 1.3ppb
Copper (ppm)	1.3	0.4	9/20	No		0ppm 0.5ppm

Microbial Contaminants	MCL	MCLG	Number of Detections	Violation	Source
Total Coliform Bacteria	1 positive monthly sample (Positive in ≥ 5% of samples)		0	No	Naturally present in the environment.
Special Sampling	MCL	MCLG	Level Detected	Sample Date	Typical Source of Contaminant
Haloacetic Acids (ppb)	60	n/a	<0.38	2021	Byproduct of drinking water disinfection.
Total Trihalomethanes (ppb)	80	n/a	4.2	2021	Byproduct of drinking water disinfection.

STATEMENT ABOUT LEAD: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Crystal Falls is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line, it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The City of Crystal Falls water supply has a total of 893 water service lines 22 contain portions of lead 871 contain neither lead nor galvanized previously connected to lead.

Monitoring and reporting to the Michigan Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the USEPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2021.

We will update this annually and will keep you informed of any problems that may occur throughout the year as they happen. This Consumer Confidence Report is available at www.crystalfalls.org. If you do not have access to the internet, you can request a copy by calling the clerks office at 906-875-3212. This report will not be sent to you.

For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.